



ANDUM PROTECTIVE EQUIPMENT TECHNOLOGY (CHANGZHOU)CO.,LTD  
Address: No. 216, Qianjie, Hengshanqiao Town, Changzhou Economic Zone,  
Changzhou City, Jiangsu Province, China.

## EU Vyhlásenie o zhode

Podľa nariadenia (EU) 2016/425

Výrobca:	AnDum Protective Equipment Technology (Changzhou) Co., Ltd.
Adresa:	No.216, Qianjie,Hengshanqiao Town, Changzhou Economic Zone, Changzhou City, Jiangsu Province, China.
Európsky zástupca:	MedPath GmbH Adresa : Mies-van-der-Rohe-Strasse 8,80807 Munich, Germany
Meno Produktu:	Filtering Half Mask - Respirátor
Klasifikácia:	FFP2 NR
Model produktu :	AD-1001
Veľkosť produktu:	15 cm x 10 cm
farba	<b>Rôzne farby</b>
Název výrobcu:	AnDum
Posudzovanie zhody podle platnej direktívy:	Zhoda s typom založená na internej kontrole výroby a kontrolách výrobkov pod dohľadom v náhodných intervaloch (modul C2) pod dohľadom notifikovaného orgánu NB 2163 Universal Certification and Surveillance Service Trade Ltd. Co. (certifikát č. 2163-PPE-640)
Platný standard:	EN 149:2001 + A1:2009 Ochranné prostriedky dýchacích orgánov Respirátory na ochranu pred časticami. Požiadavky, skúšanie, označovanie

Podpísaný subjekt týmto prehlasuje, že uvedené osobné ochranné prostriedky vyhovujú transpozícii do vnútroštátneho práva, ustanoveniam nariadenia Rady (EÚ) 2016/425 a základným požiadavkám na zdravie a bezpečnosť uvedeným v prílohe II. Notifikovaný orgán NB 2163 Universal Certification and Surveillance Service Trade Ltd. Co. vykonal EÚ skúšku typu (modul B) podľa prílohy V a vydal certifikát EÚ skúšky typu č. 2163-PPE-640. Všetka podporná dokumentácia sa uchováva u výrobcu. **Toto vyhlásenie o zhode bolo vydané na výhradnú zodpovednosť výrobcu.**

zástupca CE: MedPath GmbH  
Adresa: Mies-van-der-Rohe-Strasse 8, 80807 Munich, Germany

Podpis ( v mene výrobcu ) WEIXING YU  
Pozícia v spoločnosti : General Manager



podpísané dňa : May.06, 2020  
Miesto: Changzhou, Jiangsu, China



## EU TYPE EXAMINATION CERTIFICATE

**Certificate Nr: 2163-PPE-640**

Respiratory protective devices, filtering half masks to protect against particles manufactured by

**AnDum Protective Equipment Technology (Changzhou) Co., Ltd.**

No.63 Donghu Road, Henglin town, Wujin Area, Changzhou, Jiangsu, CHINA

are tested and evaluated according to

**EN 149:2001+A1:2009 Respiratory Protective Devices -  
Filtering Half Masks To Protect Against Particles -  
Requirements, Testing, Marking**

Based on the type examination conducted with the evaluation of test reports, technical file according to Personal Protective Equipment Regulation (EU) 2016/425 Annex 5, it is approved that the product meets the requirements of the regulation. The details of essential requirement compliance is given in technical report numbered 2163-PPE-641.

**Product Definition**

**Brand Name:** AnDum **Model:** AD-1001

Filtering half mask

**Total Inwards Leakage:** Class – FFP2

Here by the manufacturer is allowed to use notified body number (2163) and can fix CE mark, as shown below, on the Category III product models given above, with;

- Issuing an appropriate EU Declaration of Conformity according to **Personal Protective Equipment Regulation (EU) 2016/425 Annex 9**.
- Ongoing successful performance in fulfilment of the requirements set out in Personal Protective Equipment Regulation (EU) 2016/425 and harmonised standards, ensured by assessments based on **Annex 7 (Module C2) or Annex 8 (Module D)** of the regulation no later than 1 year from the beginning of serial production

This certificate is initially issued on **28/04/2020** and will be valid for 5 years if there is no change in the relevant harmonised standard affecting the essential health and safety requirements.




Suat KAÇMAZ  
UNIVERSAL CERTIFICATION  
Director

The validity of this certificate can be verified online.

## CERTIFIKÁT EU O TYPU PŘEZKOUŠENÍ

**Certifikát číslo: 2163-PPE-640**

Ochranné prostředky dýchacích orgánů, filtrační polomasky na ochranu před částicemi vyrobenými firmou

**AnDum Protective Equipment Technology (Changzhou) Co., Ltd.**

číslo.63 Donghu Road, Henglin town, Wujin Area, Changzhou, Jiangsu, CHINA

jsou testovány a hodnoceny podle

**EN 149:2001+A1:2009 Ochranné prostředky  
dýchacích orgánů - Filtrační masky na ochranu proti částicím -  
Požadavky, testování, značení**

Na základě typové zkoušky provedené s hodnocením protokolů o zkouškách, technické dokumentace podle nařízení o osobních ochranných prostředcích (EU) 2016/425, příloha 5, je schválen že produkt splňuje požadavky nařízení. Podrobnosti základního požadavku shoda je uvedena v technické zprávě číslované 2163-PPE-641.

**Popis produktu**

**Název :** AnDum Model: AD- 1001

Respirační maska

**Ochranná třída propustnosti :** Class - FFP2

Zde může výrobce používat číslo oznámeného subjektu (2163) a může opravit značku CE, jak je ukázáno níže, u výše uvedených modelů produktů s kategorií III;

- Vydání příslušného prohlášení EU o shodě podle nařízení o osobních ochranných prostředcích (EU) 2016/425, příloha 9.
- Prohlášení úspěšný výkon při plnění požadavků stanovených v nařízení o osobních ochranných prostředcích (EU) 2016/425 a harmonizovaných normách zajištěných posouzeními na základě přílohy 7 (modul C2) nebo přílohy 8 (modul I) nařízení nesmí být starší než 1 rok od začátku sériové výroby

Tento certifikát je původně vydán dne 28/04/2020 a bude platný po dobu 5 let, pokud není změna příslušné legislativní normy ovlivňující základní zdraví a bezpečnost




Suat KAÇMAZ  
UNIVERSAL CERTIFICATION  
Director

Platnost tohoto certifikátu si můžete ověřit online.







# EU TYPE EXAMINATION CERTIFICATE

**Certificate No: 2163-PPE-640**

Respiratory protective devices, filtering half masks to protect against particles manufactured by  
**AnDum Protective Equipment Technology (Changzhou) Co., Ltd.**  
 No. 216, Qianjie, Hengshanqiao Town, Changzhou Economic Zone, Changzhou City,  
 Jiangsu Province, China

are tested and evaluated according to

## **EN 149:2001 + A1:2009 Respiratory Protective Devices - Filtering Half Masks to Protect Against Particles - Requirements, Testing, Marking**

Based on the type examination conducted with the evaluation of test reports, technical file according to Personal Protective Equipment Regulation (EU) 2016/425 Annex 5, it is approved that the product meets the requirements of the regulation.

### **Product Definition**

Single shift use particle filtering half mask for protection against solid and liquid aerosols, is a folding type, 5 layers cotton and polypropylene fabrics, without valve, fitted with ear loops, with inside nose clip.

**Brand Name:** AnDum **Model:** AD-1001 **Classification:** FFP2 NR

*Model have Light Green, Rose, Dark Green, Atrovirens, Orange, Bright Red, Pink, Light Blue, Dark Blue, Purple, Cream, Gray, Coffee, Black, Slate Blue and Camouflage versions*

Here by the manufacturer is allowed to use notified body number (2163) and can fix CE mark, as shown below, on the Category III product models given above, with;

- Issuing an appropriate EU Declaration of Conformity according to **Personal Protective Equipment Regulation (EU) 2016/425 Annex 9.**
- Ongoing successful performance in fulfilment of the requirements set out in Personal Protective **Equipment Regulation (EU) 2016/425** and harmonised standards, ensured by assessments based on **Annex 7 (Module C2) or Annex 8 (Module D)** of the regulation

This certificate is initially issued on **28/04/2020** and will be valid for 5 years, if there is no change in the relevant harmonised standard affecting the essential health and safety requirements.



Suat KAÇMAZ  
 UNIVERSAL CERTIFICATION  
 Director

*This certificate is re-issued on 16.12.2020 (Rev1) with coloured versions of the model. For details refer to the technical evaluation report provided to the manufacturer.*



**TECHNICAL ASSESSMENT REPORT**

**REPORT DATE / NO:** 16.12.2020 / 2163-KKD-641 /R1

*Initial Report Date and Number:* 28.04.2020 / 2163-KKD-641

*This technical evaluation report is enriched and updated with the use of the same fabric as defined in the initial technical file with colored versions in the outer most layer of the mask and earloops. There is no other design or material change in the colored versions of the model. See relevant test reports on the material innocuousness of the material.*

**Manufacturer:** AnDum Protective Equipment Technology (Changzhou) Co., Ltd.

**Address:** No. 216, Qianjie, Hengshanqiao Town, Changzhou Economic Zone, Changzhou City, Jiangsu Province, China

This report is for the, given above, manufacturer, prepared according to the test results obtained from Ningbo Customs District Technology Center accredited by CNAS (Chinese Accreditation Body), signatory to ILAC MRA, with number CNAS L0317 for the product identified below, dated 03.08.2020 with Number KZ2021740 based on EN 149: 2001 + A1: 2009 standard and test reports on the material safety by means of toxic, carcinogen, irritation and sensitivity evaluation.

The technical file of the manufacturer dated 03.12.2020 version 1, and risk evaluation against the essential health safety requirements and the test report evaluated for their relation with Essential Requirements of Personal Protective Equipment Regulation and found to be appropriate.

This report is an annex and an integral part of the EU Type Examination Certificate issued to the manufacturer. The test results and issued certificate belongs only to the tested model. The technical report consists of a total of 6 pages.

**Product Description:** Single shift use particle filtering half mask for protection against solid and liquid aerosols, is a folding type, 5 layers cotton and polypropylene fabrics, without valve, fitted with ear loops, with inside nose clip.

**Component and Materials:**

Component	Material	Grade / Size
1st layer (Outer)	Non-Woven Fabric	60 g/m <sup>2</sup> (±2 g/m <sup>2</sup> )
2nd layer	ES Heat sealing cotton	35 g/m <sup>2</sup> (±2 g/m <sup>2</sup> )
3rd layer	Melt-blown - non-woven fabric	25 g/m <sup>2</sup> (±2 g/m <sup>2</sup> )
4th layer	Melt-blown - non-woven fabric	25 g/m <sup>2</sup> (±2 g/m <sup>2</sup> )
5th layer (Inner)	Non-Woven Fabric	28 g/m <sup>2</sup> (±2 g/m <sup>2</sup> )
Internal Nose Clip	PE White Plastic	81 mm (±2 mm)
Ear Loop	Chinlon	18.5 cm (±2 cm)

**Classification:** FFP2 NR

**Brand Name:** AnDum **Model:** AD-1001

Colored samples of the mask





**THE CLAUSES OF EN 149: 2001 + A1: 2009 STANDARD RELATED TO EUROPEAN UNION DIRECTIVE  
EU 2016/425 REQUIREMENTS**

**1.1. Design principles**

**1.1.1. Ergonomics**

PPE must be so designed and manufactured that in the foreseeable conditions of use for which it is intended the user can perform the risk related activity normally whilst enjoying appropriate protection of the highest possible level.

**1.1.2. Levels and classes of protection**

**1.1.2.1. Highest level of protection possible**

The optimum level of protection to be taken into account in the design is that beyond which the constraints by the wearing of the PPE would prevent its effective use during the period of exposure to the risk or normal performance of the activity.

**1.1.2.2. Classes of protection appropriate to different levels of risk**

Where differing foreseeable conditions of use are such that several levels of the same risk can be distinguished, appropriate classes of protection must be taken into account in the design of the PPE.

**1.2. Innocuousness of PPE**

**1.2.1. Absence of risks and other inherent nuisance factors**

PPE must be so designed and manufactured as to preclude risks and other nuisance factors under foreseeable conditions of use.

**1.2.1.1. Suitable constituent materials**

The materials of which the PPE is made, including any of their possible decomposition products, must not adversely affect the health or safety of users.

**1.2.1.2. Satisfactory surface condition of all PPE parts in contact with the user**

Any part of the PPE that is in contact or is liable to come into contact with the user when the PPE is worn must be free of rough surfaces, sharp edges, sharp points and the like which could cause excessive irritation or injuries

**1.2.1.3. Maximum permissible user impediment**

Any impediment caused by PPE to movements to be made, postures to be adopted and sensory perception must be minimized; nor must PPE cause movements which endanger the user or other persons.

**1.3 Comfort and effectiveness**

**1.3.1. Adaptation of PPE to user morphology**

PPE must be designed and manufactured in such a way as to facilitate its correct positioning on the user and to remain in place for the foreseeable period of use, bearing in mind ambient factors, the actions to be carried out and the postures to be adopted. For this purpose, it must be possible to adapt the PPE to fit the morphology of the user by all appropriate means, such as adequate adjustment and attachment systems or the provision of an adequate range of sizes.

**1.3.2. Lightness and design strength**

PPE must be as light as possible without prejudicing design strength and efficiency.

Apart from the specific additional requirements which they must satisfy in order to provide adequate protection against the risks in question (see 3), PPE must be capable of withstanding the effects of ambient phenomena inherent under the foreseeable conditions of use

**1.4. Information supplied by the manufacturer**

The notes that must be drawn up by the former and supplied when PPE is placed on the market must contain all relevant information on:

- In addition to the name and address of the manufacturer and/or his authorized representative established in the Community
- Storage, use, cleaning, maintenance, servicing and disinfection. cleaning, maintenance or disinfectant protection recommended by manufacturers must have no adverse effect on PPE or users when applied in accordance with the relevant instructions;
- Performance as recorded during technical tests to check the levels or classes of protection provided by the PPE in question;
- Suitable PPE accessories and the characteristics of appropriate spare parts;
- The classes of protection appropriate to different levels of risk and the corresponding limits of use;
- The obsolescence deadline or period of obsolescence of PPE or certain of its components;
- The type of packaging suitable for transport;
- The significance of any markings (see 2.12)
- Where appropriate the references of the Directives applied in accordance with Article 5(6) (b);
- The name, address and identification number of the notified body involved in the design stage of the PPE

These notes, which must be precise and comprehensible, must be provided at least in the official language(s) of the member state of destination





## 2. ADDITIONAL REQUIREMENTS COMMON TO SEVERAL CLASSES OR TYPES OF PPE

### 2.1. PPE incorporating adjustment systems

If PPE incorporates adjustment systems, the latter must be designed and manufactured so that, after adjustment, they do not become undone unintentionally in the foreseeable conditions of use.

### 2.3. PPE for the face, eyes and respiratory system

Any restriction of the user's face, eyes, field of vision or respiratory system by the PPE shall be minimised.

The screens for those types of PPE must have a degree of optical neutrality that is compatible with the degree of precision and the duration of the activities of the user.

If necessary, such PPE must be treated or provided with means to prevent misting-up.

Models of PPE intended for users requiring sight correction must be compatible with the wearing of spectacles or contact lenses.

### 2.4. PPE subject to ageing

If it is known that the design performance of new PPE may be significantly affected by ageing, the month and year of manufacture and/or, if possible, the month and year of obsolescence must be indelibly and unambiguously marked on each item of PPE placed on the market and on its packaging.

If the manufacturer is unable to give an undertaking with regard to the useful life of the PPE, his instructions must provide all the information necessary to enable the purchaser or user to establish a reasonable obsolescence month and year, taking into account the quality level of the model and the effective conditions of storage, use, cleaning, servicing and maintenance.

Where appreciable and rapid deterioration in PPE performance is likely to be caused by ageing resulting from the periodic use of a cleaning process recommended by the manufacturer, the latter must, if possible, affix a marking to each item of PPE placed on the market indicating the maximum number of cleaning operations that may be carried out before the equipment needs to be inspected or discarded. Where such a marking is not affixed, the manufacturer must give that information in his instructions.

### 2.6. PPE for use in potentially explosive atmospheres

PPE intended for use in potentially explosive atmospheres must be designed and manufactured in such a way that it cannot be the source of an electric, electrostatic or impact-induced arc or spark likely to cause an explosive mixture to ignite.

### 2.8. PPE for intervention in very dangerous situations

The instructions supplied by the manufacturer with PPE for intervention in very dangerous situations must include, in particular, data intended for competent, trained persons who are qualified to interpret them and ensure their application by the user.

The instructions must also describe the procedure to be adopted in order to verify that PPE is correctly adjusted and functional when worn by the user.

Where PPE incorporates an alarm which is activated in the absence of the level of protection normally provided, the alarm must be designed and placed so that it can be perceived by the user in the foreseeable conditions of use.

### 2.9. PPE incorporating components which can be adjusted or removed by the user

Where PPE incorporates components which can be attached, adjusted or removed by the user for replacement purposes, such components must be designed and manufactured so that they can be easily attached, adjusted and removed without tools.

### 2.12. PPE bearing one or more identification or recognition marks directly or indirectly relating to health and safety

The identification or recognition marks directly or indirectly relating to health and safety affixed to these types or classes of must preferably take the form of harmonized pictograms or ideograms and must remain perfectly legible throughout the foreseeable useful life of the PPE. In addition, these marks must be complete, precise and comprehensible so as to prevent any misinterpretation; in particular, where such marks incorporate words or sentences, the latter must appear in the official language(s) of the Member State where the equipment is to be used.

If PPE (or a PPE component) is too small to allow all or part of the necessary marking to be affixed, the relevant information must be mentioned on the packing and in the manufacturer's notes.

## 3. ADDITIONAL REQUIREMENTS SPECIFIC TO PARTICULAR RISKS

### 3.10.2. Protection against cutaneous and ocular contact

PPE intended to prevent the surface contact of all or part of the body with substances and mixtures which are hazardous to health or with harmful biological agents must be capable of preventing the penetration or permeation of such substances and mixtures and agents through the protective integument under the foreseeable conditions of use for which the PPE is intended.

To this end, the constituent materials and other components of those types of PPE must be chosen or designed and incorporated so as to ensure, as far as possible, complete leak-tightness, which will allow where necessary prolonged daily use or, failing this, limited leak-tightness necessitating a restriction of the period of wear.

Where, by virtue of their nature and the foreseeable conditions of their use, certain substances and mixtures which are hazardous to health or harmful biological agents possess high penetrative power which limits the duration of the protection provided by the PPE in question, the latter must be subjected to standard tests with a view to their classification on the basis of their performance. PPE which is considered to be in conformity with the test specifications must bear a marking indicating, in particular, the names or, in the absence of the names, the codes of the substances used in the tests and the corresponding standard period of protection. The manufacturer's instructions must also contain, in particular, an explanation of the codes (if necessary), a detailed description of the standard tests and all appropriate information for the determination of the maximum permissible period of wear under the different foreseeable conditions of use.





Technical Assessment of EN 149: 2001 + A1: 2009 Standard and other Standards it refers to, Clauses Corresponding to the  
(EU) 2016/425 Directive

Conforming to EN 149:2001 + A1:2009 Standard Requirements																												
Article 5	<p><b>Classification:</b> Particle Filtering Half Mask</p> <p>The mask subject to evaluation based on the test results and technical file provided by the manufacturer is classified as; Filtering Efficiency and Maximum Total Inward Leakage: Classified as FFP2</p> <p>Mask is classified for single shift use, NR</p>																											
Article 7.4	<p><b>Packing:</b> Particle filtering half masks are packaged to protect them from contamination before use and with cardboard boxes to prevent mechanical damage. The packaging design and the product is considered to withstand the foreseeable conditions of use based on the visual inspection results given in the test report. Details given in Annex 9.1 of Technical File</p>																											
Article 7.5	<p><b>Material:</b> Materials used in particle filtering half masks, according to the simulated wearing treatment and temperature conditioning results; It is understood it withstands handling and wear over the period for which the particle filtering half mask is designed to be used, it suffered mechanical failure of the facepiece or straps, any material from the filter media released by the air flow through the filter has not constitute a hazard or nuisance for the wearer. The manufacturer declares that the materials used in manufacturing of the mask does not have an adverse affect to the health and safety of users. Manufacturer declares that the material do not have any adverse effect for the wearers health in Section 7 of the Technical File.</p> <p>Based on the test results, the masks did not collapse when subject to simulated wearing and temarature conditioning. No nuisance situation is reported during the practical performance tests by human subjects.</p> <p><i>The model have colored ones manufactured by use of colored spunbound fabrics in the most outer layer of the mask, with the earloops as well. Based on the test results in the test report of TÜV THURINGEN (SHANGHAI) Co. Ltd., (Report numbers 8621.SH.2011.0111 (LightGreen), 8621.SH.2011.0112 (Rose), 8621.SH.2011.0113 (DarkGreen), 8621.SH.2011.0114 (Atrovirens), 8621.SH.2011.0115 (Orange), 8621.SH.2011.0116 (Bright Red), 8621.SH.2011.0117 (Pink), 8621.SH.2011.0118 (Light Blue), 8621.SH.2011.0119 (Dark Blue), 8621.SH.2011.0120 (Purple), 8621.SH.2011.0121 (Cream), 8621.SH.2011.0122 (Gray), 8621.SH.2011.0123 (Coffee), 8621.SH.2011.0124 (Black), 8621.SH.2011.0125 (Slate Blue) and 8621.SH.2011.0126 (Camouflage), REACH SVHC content reports. Based on the results the colored materials (spunbound fabric) used in the most outer layer of the mask is considered to be safe for use on the mask. Annexed sample photos of the colored masks.</i></p>																											
Article 7.6	<p><b>Cleaning and Disinfection:</b> Particle filtering half mask is <b>not</b> designed to be as re-usable. No cleaning or disinfection procedure provided by the manufacturer.</p>																											
Article 7.7	<p><b>Practical Performance :</b></p> <p>The test report indicates that the human subjects did not face any difficulty in performing the excercises while they were weared by the sample masks, in walking test or work simulation tests. The wearers did not report any failure by means of head harness / straps/ earloops comfort, security of fastenings and field of vision. Also no imperfections reported during total inward tests about the comfort, field of vision and fastening issues.</p> <table><tr><th>Assessed Elements</th><th>Positive</th><th>Negative</th><th>Requirements in accordance with EN 149:2001 + A1:2009 and Result</th></tr><tr><td>1.The face piece fitting</td><td>2</td><td>0</td><td rowspan="6">Positive results are obtained from the performance tests related to the implementation under real conditions, applied with the compatibility with skin evaluation (7.10).</td></tr><tr><td>2.Head harness comfort</td><td>2</td><td>0</td></tr><tr><td>3.Security of fastenings</td><td>2</td><td>0</td></tr><tr><td>4.Speech clearness</td><td>2</td><td>0</td></tr><tr><td>5.Field of vision</td><td>2</td><td>0</td></tr><tr><td>6.Materials compatibility with skin</td><td>10</td><td>0</td></tr><tr><td colspan="3"><b>Conditioning : (A.R.) As Received, original</b></td><td><b>No imperfections</b></td></tr></table>	Assessed Elements	Positive	Negative	Requirements in accordance with EN 149:2001 + A1:2009 and Result	1.The face piece fitting	2	0	Positive results are obtained from the performance tests related to the implementation under real conditions, applied with the compatibility with skin evaluation (7.10).	2.Head harness comfort	2	0	3.Security of fastenings	2	0	4.Speech clearness	2	0	5.Field of vision	2	0	6.Materials compatibility with skin	10	0	<b>Conditioning : (A.R.) As Received, original</b>			<b>No imperfections</b>
Assessed Elements	Positive	Negative	Requirements in accordance with EN 149:2001 + A1:2009 and Result																									
1.The face piece fitting	2	0	Positive results are obtained from the performance tests related to the implementation under real conditions, applied with the compatibility with skin evaluation (7.10).																									
2.Head harness comfort	2	0																										
3.Security of fastenings	2	0																										
4.Speech clearness	2	0																										
5.Field of vision	2	0																										
6.Materials compatibility with skin	10	0																										
<b>Conditioning : (A.R.) As Received, original</b>			<b>No imperfections</b>																									
Article 7.8	<p><b>Finish of Parts:</b> Particle filtering half masks, which are likely to come into contact with the user, do not have sharp edges and do not contain burrs.</p>																											
Article 7.9.1	<p><b>Total Inward Leakage:</b></p> <p>The Total Inward Leakage test is conducted by 10 individual in an aerosol chamber with a walking band, and samples are taken during the conduction of the excercises defined in the standard. The samples used in the test are subjected to the conditioning required in the standard as temperature conditioning and as received. The face dimensions of the subjects are also reported. The measurement details for each subject and for each excersize are available in the test report.</p> <p>It was reported that;</p> <p>All 50 exercise measurement results are smaller or equal to 11%, According to the results maximum measurement is 8,33 %.</p> <p>All 10 individual's arithmetic mean is smaller or equal to 8%, According to the results the means for 10 subject varies between 3,63 % to 6,84 %.</p> <p>According to the reported results, the product meets the limits for FFP1 and FFP2 classification.</p>																											





Article 7.9.2	Penetration of filter material: Sodium Chloride Testing					
	Condition	No. of Sample	Sodium Chloride Testing 95 L/min max (%)	Requirements in accordance with EN 149:2001 + A1:2009	Result	
	(A.R.)	19	0,77	FFP1 ≤ 20 %  FFP2 ≤ 6 %  FFP3 ≤ 1 %	Filtering half masks fulfill the requirements of the standard EN EN 149:2001 + A1:2009 given in 7.9.2 in range of the first, and second protection classes. <b>FFP1, FFP2</b>	
	(A.R.)	20	1,07			
	(A.R.)	21	1,03			
	(S.W.)	22	1,20			
	(S.W.)	23	1,40			
	(S.W.)	24	1,66			
	(M.S. T.C.)	25	1,73			
	(M.S. T.C.)	26	1,43			
(M.S. T.C.)	27	1,69				
Conditioning : (M.S.) Mechanical Strength (T.C.) Temperature Conditioning (A.R.) As Received, original (S.W.) Simulated wearing treatment						
95 L/min = 1,6 dm³.s⁻¹						
Article 7.9.2	Penetration of filter material: : Paraffin Oil Testing					
	Condition	No. of Sample	Paraffin Oil Testing 95 L/min max (%)	Requirements in accordance with EN 149:2001 + A1:2009	Result	
	(A.R.)	28	2,17	FFP1 ≤ 20 %  FFP2 ≤ 6 %  FFP3 ≤ 1 %	Filtering half masks fulfill the requirements of the standard EN EN 149:2001 + A1:2009 given in 7.9.2 in range of the first and second protection classes. <b>FFP1, FFP2</b>	
	(A.R.)	29	2,45			
	(A.R.)	30	2,08			
	(S.W.)	31	4,17			
	(S.W.)	32	4,47			
	(S.W.)	33	4,38			
	(M.S. T.C.)	34	5,57			
	(M.S. T.C.)	35	5,43			
(M.S. T.C.)	36	5,60				
Conditioning : (M.S.) Mechanical Strength (T.C.) Temperature Conditioning (A.R.) As Received, original (S.W.) Simulated wearing treatment						
Article 7.10	Compatibility with skin: In Practical Performance report, the likelihood of mask materials in contact with the skin causing irritation or other adverse effect on health was not reported.					
Article 7.11	Flammability :					
	Condition	No. of Sample	Visual inspection	Requirements in accordance with EN 149:2001 + A1:2009	Result	
	(A.R.)	42	0 s	Filtering half mask shall not burn or not continue to burn for more than 5 s after removal from the flame	Passed  Filtering half masks fulfill requirements of the standard	
	(A.R.)	43	0 s			
	(T.C.)	44	0 s			
(T.C.)	45	0 s				
Conditioning : (A.R.) As Received, original (T.C.) Temperature Conditioning						
Article 7.12	Carbon dioxide content of the inhalation air:					
	Condition	No. of Sample	CO₂ content of the inhalation air [%] by volume	An average CO₂ content of the inhalation air	Requirements in accordance with EN 149:2001 + A1:2009	Result
	(A.R.)	46	0,27	0,27	CO₂ content of the inhalation air shall not exceed an average of 1,0% by volume	Passed  Filtering half masks fulfill requirements of the standard
	(A.R.)	47	0,28			
	(A.R.)	48	0,27			
Conditioning : (A.R.) As Received, original						
Article 7.13	Head harness: In Practical Performance and TIL test reports no adverse effects have been reported for donning and remove of the mask also the results of these tests indicates that the head harnesses are capable of holding the mask firmly enough.					
Article 7.14	Field of vision: In Practical Performance report, no adverse effects were reported for the field of vision availability when the mask is worn.					
Article 7.16	Breathing Resistance: Inhalation					
	The overall evaluation in the figures gathered for 9 different samples 3 as received, 3 with temperature conditioning and 3 Ssimulated wearing conditioned, complies with the limits given in the standard for FFP1, FFP2 and FFP3 classes. This is valid for inhalation results for 30 L/min, 95 L/min and exhalation at 160 L/min.  Passed.					



Article 7.17.2	<b>Clogging:</b> This test is not applied to Particle Filtering Half Mask which is not reusable. (For single shift use devices, the clogging test is optional test. For re-usable devices test is mandatory.)
Article 7.17.3	<b>Penetration of filter material:</b> This test is not applied to Particle Filtering Half Mask which is not reusable.
Article 7.18	<b>Demountable Parts:</b> There are no demountable parts on the product.
Article 9	<b>Marking – Packaging:</b> Necessary markings are available on the product package (box). The name and trademark of the manufacturer is stated to exist on the carton boxes. The type of the mask and the classification including the status of re-usability, the reference to EN 149:2001+A1:2009 standard, the year of end of shelf life, using and storage instructions and pictograms and CE mark are available on the product package. The above evaluation is based on the technical document for packaging and marking, for box design. Verified on the annex 9.1 and annex 6 of the technical file.  The technical documentation for mask design (drawing) also evaluated for marking requirements, drawing Annex 6. The mask template (drawing) indicates that the mask will carry information about the brandname of the manufacturer, type of mask, the reference to EN 149+A1:2009 standard and classification including the re-usability of the mask. The manufacturer also printed CE mark with our Notified Body number. The mask do not have sub-assemblies. The tested samples by the laboratory carry necessary marking information as stated in the technical documentation, the manufacturer shall follow marking instructions for serial production. AD-1001 drawing which exists in the technical file of the manufacturer, Annex 6 of technical file.  The manufacturer shall pay attention on the colored samples that the markings shall be easily readable on the mask.
Article 10	<b>Information to be supplied by the manufacturer:</b> In each of the smallest commercially available packaging of the product, implementation (installation instructions) pre-use controls, warning and usage limitations, storage and meanings of symbols / pictograms are defined. User instruction document in the technical file found to be appropriate, Annex 8. The manufacturer shall include this documented user information text in every smallest commercially available package.

PREPARED BY	APPROVED BY
<b>Osman CAMCI</b> PPE Expert 	<b>Suat KAÇMAZ</b> Director  